

TECHNICAL BULLETIN

COLOREX GROUNDING REQUIREMENTS

Improved Colorex grounding procedure is as follows:

A minimum of 3 lin. ft. of grounding strap on the floor is required for every 2,000 sq. ft. of tile installed. (Changed from 3 lin. ft. for every 500 sq. ft.) This improvement is a result of the addition of the Unigrind on the back of the tile and the consistency in the electrical resistance of the adhesive.

Orders will continue to be shipped with the necessary grounding straps as per new specification, along with the yellow ESD grounding tags.

For further information, please contact Forbo Support Services @ 800-233-0475 ext. 218